

ADDENDUM TO INSTRUCTIONS TO BIDDERS

Owner: Board of Education of the Wayne Local School District

Project: Stadium Field Turf & Track Replacement Project

Response Deadline: January 2, 2025, at noon, local time.

Addendum No. 1

The Owner hereby informs all known interested bidders of the following revisions to the ITB. A revised copy of the ITB is available on request to Ryan Fullenkamp, Director of Operations at rfullenkamp@waynelocal.net, and will be posted on the District website.

The following sections of the ITB have been revised.

I. SECTION 2. SCOPE OF WORK

All bidders may submit a standard equivalent to any brand specified herein.

The scope of work includes, but is not limited to, the following tasks:

1. Turf Replacement:

a. Demolition

- i. Replace existing turf field and add field event (Pole Vault)
- ii. Remove and haul off existing turf

b. Inspect drainage

c. Excavate for pole vault

- i. Remove excess stone
- ii. Pour pole vault runway and pad
- iii. Replace nailer as needed around inside curb and install nailer around new concrete
- iv. Smooth drumroll and laser grade existing stone base

d. Install new flagpole in D Zone

- i. Includes running electric to play clocks and flagpole (current electric is in opposite end zone and at mid-field sideline)

e. Install synthetic turf, include the following:

- i. Colored turf endzones with "SPARTANS" lettering

- ii. Centerfield logo
 - iii. Football, Soccer, and Lacrosse lines and numbers
- f. Turf specifications (50 oz dual fiber with thatch)
 - i. Pile height: 2"
 - ii. Face weight: 50 oz/sqyd
 - iii. Total fabric weight: 77 oz/sqyd
 - iv. Tuft bind: >10 lbs
 - v. Water permeability: >30 in/hr
 - vi. Fiber thickness: 9.4 mils
- g. Pre-approved product: Sporturf Gamechanger T50
- h. Install infill (based on manufacture recommendations) and groom field
- i. Warranty: Standard 8-year required on all material and workmanship
- j. After-care and Maintenance at 1-year anniversary:
 - i. Includes Turf inspection and repair, field cleaning, magnet sweep, field disinfection, GMAX Impact test, and Field report.

II. SECTION 7. APPROVAL BEFORE BIDDING

.1 If a Contractor preparing bids for submission on the Work is in doubt as to the acceptability of a manufacturer's material or equipment, under the requirements as set forth in these instructions to bidders, he should require that representatives of the proposed manufacturer or supplier contact the Owner's Liaison and request a ruling on the acceptability of the material or equipment in question. The contact should be made in sufficient time, 10 days before the date scheduled for the closing of bids, so that an addendum can be issued to clarify the situation.

.2 It is not possible to set the time allowance for every problem; however, it shall be not less than 10 days before bid closing. Each party requesting a ruling under this Article shall be responsible for the proper evaluation of the time involved and shall submit their request in ample time to process it.


.3 Prior to receipt of bids, the Owner's Liaison will consider proposals for substitution of materials, equipment, and methods only when such proposals are submitted in writing at least 10 days before the date set for receipt of bids, and are accompanied by full and complete technical data and other information required by the Owner's Liaison to evaluate the proposed substitution.

.4 Each bidder understands that past acceptance of products does not assure acceptance on this Project. Products not specifically specified require requests for approval prior to the bid due date.

Notwithstanding the foregoing, the Owner will consider and approve alternate manufacturers for materials and equipment submitted prior to 4:00 p.m. on December 29, 2025.

All remaining terms of the ITB remain in full force and effect.

12/22/2025
Date


Carolyn Huber, Treasurer

[END OF DOCUMENT]